

HCL.

Price

ARGYLE CREEK WATER COMMISSIONER'S REPORT

By: John Bene, Court-appointed Water Commissioner
June 25, 1964

Water rights under Jacob Johnson Decree:

Nev Wimmer place (on Nine Mile Creek)	1.28 cfs
Mills	0.74 cfs
Clive Sprouse (Llewellyn, operator 1964)	0.51 cfs
Umbert Pressett	0.40 cfs
Preston Nutter Corp.	1.40 cfs
	<hr/> 4.33 cfs

Mills (under application and certificated filing priority of 1954)	5.00 cfs
Preston Nutter Corp. (Priority of 3/5/57)	
Under Application #28912	5.00 cfs
Under Application #28913	5.00 cfs

No water being diverted on upper Wimmer place (old Gibney place). No authorized diversion.

Old Houskeeper place: No water being diverted.

Pressett place: Is diverting 1.60 cfs. 9" Parshall flume in place and operational. Note: Water is not being tended and as a result most of the water is running back into Argyle Creek.

Nev Wimmer: Diverting 1.80 cfs. Water was being tended by Mr. Wimmer and was fully used. Diversion control and 9" Parshall flume are operational.

Henry Mills: Diverting 1.30 cfs. on the north side of Argyle Creek; 2.10 cfs. was being diverted on the south side of Argyle Creek diversion works and measuring devices in both cases are operational. Note: most of the water is returning directly to Argyle Creek; not being tended. 9" Parshall flumes.

Clive Sprouse place (old Hayes place) operator, 1964 Llewellyn: No measuring device. Parshall flume taken out by flood last fall. Water measured through Armco control gate - 0.92 cfs.

Preston Nutter Corp.: All control gates and measuring devices operational. North side diversion, 3.29 cfs; south side diversion, 1.72 cfs. 12" Parshall flumes. Two men tending water. Diversion below ranch headquarters diverting 0.92 cfs. under application #28912. Approximately one-half second passing over and through diversion dam. 12" Parshall flume and control works operational.

If and when Henry Mills and Umbert Pressett reset their water and tend it, the available water for other users down stream will be cut back to the Johnson Decree. Preston Nutter Corp., which is the last user down stream from all the others under the Johnson Decree, can divert their Johnson Decree water plus any available water under applications #28912 and #28913.

Mr. Llewellyn on the Clive Sprouse place has been instructed to install within ten days a measuring device, or as soon as practical. Henry Mills on Argyle Creek can draw water on his certificated right covered under a 5 cfs. filing dated in 1954 if and when a ll other rights are filled under the Johnson Decree.

cc: Preston Nutter Corp. - Nine Mile
Nev Wimmer - Nine Mile
Clive Sprouse - Roosevelt
Umbert Pressett - Nine Mile
Henry Mills - Price
E. J. Skeen - 522 Newhouse Bldg. - SLC
State Engineer - State Capitol - SLC
Ed Clyde - 351 South State - SLC

